

Develop your emergency response plan

You've invested a lot of time and money in your business. That's why it's so important for you to have a plan to help protect your assets during an emergency or disaster.

Of course, some emergencies aren't preventable—like hurricanes, tornadoes, floods, and earthquakes. But others, like fires, spills, and injuries, can be addressed with safety controls. No matter the emergency, preplanning your response strategy is key. We have some suggestions below to help you. We've also included a sample checklist for your evacuation plan.

While we can't predict every type of emergency, we suggest your strategy include action plans in these key areas:

- **Inspections:** Locate and eliminate or control hazardous conditions. If you haven't already done so, incorporate these inspections into your programs to help prevent fires and work-related accidents.
- **Emergency equipment:** Determine the type, quantity, and placement of emergency equipment such as alarm systems, first aid supplies, and firefighting equipment. Provide training as needed and inspect or test the equipment regularly.
- Exits: Evaluate your exits for prominence, safety, and easy access. Conduct drills to ensure orderly exit procedures in the event of an emergency.
- Evacuation of personnel: Create an evacuation plan that gives people in a state of confusion the proper direction for an orderly exit. Form an emergency response committee to create and communicate the plan, train employees, and assign responsibilities.
- **Communications:** Routinely share your emergency action plan with employees. An informed group is more likely to respond to an emergency calmly.





This document is made available by Sentry Insurance Company and its subsidiaries and affiliates (collectively "Sentry") with the understanding that Sentry is not engaged in the practice of law, nor is it rendering legal advice. The information contained in this document is of a general nature and is not intended to address the circumstances of any particular individual or entity. Legal obligations may vary by state and locality. No one should act on the information contained in this document without legal advice from competent and licensed local professionals. THE INFORMATION CONTAINED IN THIS DOCUMENT IS DISTRIBUTED BY SENTRY "AS-IS," WITHOUT ANY WARRANTIES. SENTRY WILL HAVE NO LIABILITY TO ANY PERSON OR ENTITY WITH RESPECT TO ANY LOSSES OR DAMAGES CAUSED, OR ALLEGED TO HAVE BEEN CAUSED, DIRECTLY OR INDIRECTLY BY THIS DOCUMENT, REGARDLESS OF WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, TORT (INCLUDING NEGLIGENCE AND FOR PROPERTY DAMAGE AND DEATH), OR OTHER GROUNDS.

Property and casualty coverages are underwritten, and safety services are provided, by a member of the Sentry Insurance Group, Stevens Point, WI. For a complete listing of companies, visit sentry.com. Policies, coverages, benefits, and discounts are not available in all states. See policy for complete coverage details.

70-217 2749889 2/27/2023 **Sentry.com**

Evacuation response checklist

Use this guide when evaluating the elements of your emergency response program:

☐ Are any exit doors propped open?

FLOOR DIAGRAMS		EMERGENCY LIGHTING		
	Are maps outlining exit routes visibly placed on each floor?		In the event of an electrical power failure or interruption of service in the building, is automatic or manually operated emergency lighting available for building and exit stairwells?	
	Does each map include a "You are here" point of origin?			
	Are room numbers, floor, and directions provided?			
	Are directions to stairwells marked?		Are standby lights easily accessible during an emergency?	
EXI	EXIT PATHS TO STAIRWELLS		Is there an emergency generator in the building?	
	Are paths to exits straight and unobstructed?		Is it operable?	
	Are instructions posted at changes of direction en route to an emergency exit?		Is the emergency lighting tested on a regular basis? RGENCY COMMUNICATIONS	
	Are doors that don't lead to an exit prominently marked	_		
			Is there a plan to notify building occupants of an emergency evacuation?	
EM	EMERGENCY STAIRWELLS		If messengers must be used, have they been	
	Are stair treads and risers in good condition?	-	properly instructed?	
	Are stairwells free of storage or any other obstructions?	ı	Is the communication system in good working condition, maintained, and tested?	
	Are all stairwells equipped with stable handrails?		Is the communication system protected?	
	Does each emergency stairwell go directly to the grade- floor exit level without interruption? If a stairwell ends at some interim point in the building, are there clear directions at that point that show the way to the exit?		Do all occupants know how to contact a	
			central emergency building control to report a dangerous situation?	
	Is there a provision for directing occupants to refuge areas	EVA	EVACUATION ASSISTANCE ☐ Are there elderly or physically impaired persons who will need assistance during emergency evacuations?	
	out of and away from the building when they exit?			
	Is a head count completed during and after the evacuation?			
	Is there adequate emergency lighting in the stairwell?		Are provisions made for their evacuation during an emergency?	
	Are any bulbs and/or fixtures broken or missing?			
	Are floor numbers displayed prominently on both sides of exit doors?		Have you determined who will assist, how they'll be moved, and where they'll be transported?	
ELEVATORS		Re	Remember, while you can't predict every	
	Are signs prominently posted at and in elevators warning of dangers if used during fire and/or emergency evacuations?	en to	emergency, having a plan in place will help ensure an orderly and safe evacuation. Feel free o use this sample checklist or customize it to fit	
EMERGENCY EXIT DOORS		yo	our business's emergency response strategy.	
	Are all emergency exits properly identified, unobstructed, and illuminated?			
	Do all exit doors open easily in the proper direction?			
	Are all exit doors self-closing?			